

Standard Form Number: SF-GOOD-30
Revised on: May 24, 2004

Republic of the Philippines
METROPOLITAN NAGA WATER DISTRICT
40 J. Miranda Avenue, Naga City
Telephone Number: (054)472-1685/473-7813
Fax Number: (054)473-9288
E-mail Add.: mnwdbac@yahoo.com

SUPPLEMENTAL/BID BULLETIN
November 11, 2020

ADDENDUM NO. 11

PROJECT: Supply, Delivery, Installation, and Commissioning of Filtration System Designed for 32 LPS Capacity for Cararayan 4 Pumping Station with Manual Backwash, including the Supply of other Materials and Mobilization (GOODS 2020-009)

This addendum is issued to modify or amend items in the Technical Specifications of the bidding documents of the above stated project:

PER PHILGEPS POSTING AND PER ADDENDUM NO. 08	PER ADDENDUM
Technical Specifications 1 LOT - Filtration Tank Vessels with Filter Media For Cararayan 4 Pumping Station, 32 LPS I. Inclusions xxx II. Technical Specifications xxx Note: 1. xxx 7. A pressure switch should be installed on the upstream side to avoid over pressure of the vessels and pressure gauge on the upper and lower stream. Recommended distribution pressure is at 30 to 35 psi xxx	Technical Specifications 1 LOT - Filtration Tank Vessels with Filter Media For Cararayan 4 Pumping Station, 32 LPS I. Inclusions xxx II. Technical Specifications xxx Note: 1. xxx 7. A pressure switch should be installed on the upstream side to avoid over pressure of the vessels and pressure gauge on the upper and lower stream. Recommended distribution pressure is at <u>35 to 40</u> psi xxx

This shall form an integral part of the Bid Documents.

For guidance and information of all concerned.


JON LOUIE A. SANCHEZ
Chairperson, BAC

Received by the Bidder

Date _____