

**Republic of the Philippines**  
**METROPOLITAN NAGA WATER DISTRICT**  
40 J. Miranda Avenue, Naga City  
Telephone Number: (054)472-1685/473-7813  
Fax Number: (054)473-9288  
E-mail Add.: [mnwdbac@yahoo.com](mailto:mnwdbac@yahoo.com)

**SUPPLEMENTAL/BID BULLETIN**  
**September 3, 2020**

**ADDENDUM NO. 06**

**PROJECT: Supply, Build, Installation, Commissioning, and Process-Proving of 5MLD Bicol River Surface Water Treatment Plant (INFRA 2020-012)**

**This addendum is issued to modify or amend items in the Section III. Bid Data Sheet (BDS), Section VI. Specifications, Section VII. Drawings, and Section VIII. Bill of Quantities of the bidding documents of the above stated project.**

PER BIDDING DOCUMENTS	PER ADDENDUM
<p>Section III. Bid Data Sheet, Clause 12.1(b)(ii)</p> <p>Project Requirements, which shall include the following:</p> <p>a. Organizational chart for the contract to be bid xxx</p> <p>g. The Bidder shall provide Manufacturer’s Certificate of Registration to <u>ISO 9001:Quality Management System</u> to meet high standard in quality in manufacturing of UF Flat-Sheet membrane modules. Such document shall be supported by a notarized affidavit of authenticity or authenticated by Philippine Consul or the Office of the Local Chamber of Commerce within the manufacturer’s country of origin. xxx</p> <p>i. The Bidder shall submit the Manufacturer’s Standard Brochure indicating the DEFENDER Corrosion Protection System as a standard feature in the <u>in-line booster pump</u> and motor. xxx</p>	<p>Section III. Bid Data Sheet, Clause 12.1(b)(ii)</p> <p>Project Requirements, which shall include the following:</p> <p>a. Organizational chart for the contract to be bid xxx</p> <p>g. The Bidder shall provide Manufacturer’s Certificate of Registration to <b><u>ISO 9001:2015 Quality Management System</u></b> to meet high standard in quality in manufacturing of UF Flat-Sheet membrane modules. Such document shall be supported by a notarized affidavit of authenticity or authenticated by Philippine Consul or the Office of the Local Chamber of Commerce within the manufacturer’s country of origin. xxx</p> <p>i. The Bidder shall submit the Manufacturer’s Standard Brochure indicating the DEFENDER Corrosion Protection System as a standard feature in the <b><u>submersible</u></b> pump and motor xxx</p>
<p>Section VI. Specifications</p> <p><u>Section VII. Technical Specifications</u>  TERMS OF REFERENCE  Performance Specifications and Parameters</p> <p>I. Brief historical Background of Metropolitan Naga Water District (MNWD) xxx</p> <p>IV. DETAILED DESCRIPTION OF SCOPE OF WORK xxx</p> <p>➤ Design and Construction Schedule  The project shall be carried out in the following phases on the following periods. The period includes approval by the Owner of the Construction Documents.</p>	<p>Section VI. Specifications</p> <p><b><u>Section VI. Technical Specifications</u></b>  TERMS OF REFERENCE  Performance Specifications and Parameters</p> <p>I. Brief historical Background of Metropolitan Naga Water District (MNWD) xxx</p> <p>IV. DETAILED DESCRIPTION OF SCOPE OF WORK xxx</p> <p>➤ Design and Construction Schedule  The project shall be carried out in the following phases on the following periods. The period includes approval by the Owner of the Construction Documents.</p>






- (a) Detailed Design Phase - 45 Calendar days  
(b) Construction Phase (incl. acquisition of permits) - 225 Calendar days  
(c) Post Construction (Commissioning/Process Proving) Phase - 90 Calendar days

Total Project Duration is Three Hundred Sixty (360) Calendar days.

xxx

V. CONCEPTUAL DESIGN/SPECIFICATION/  
PARAMETERS/REQUIREMENTS  
WATER TREATMENT FACILITIES

a. General Information and requirements

INFLUENT QUALITY		EFFLUENT QUALITY	
Characteristics	Raw Water	2017 PNSDW Standards	Design/Target Objectives
1. Turbidity (NTU)	500	5	1.0 or less
2. Apparent Color	(pls indicate value)	10	5.0 or less
3. E. Coli	Positive	Negative/Absent	Negative/Absent

2. Solid-Liquid Separation/Filtration Process – use Flat-Sheet Ultrafiltration Membrane Modules

xxx

VI. SUBMERSIBLE PUMP

xxx

D. The in-line booster pump and motor shall be horizontally installed inside a steel shroud and submersible in nature. The equipment must have installed a DEFENDER smart device as a standard feature to protect the electric pump and motor from electrochemical corrosion and galvanic currents, passivating the steel so as to create a further safety barrier against corrosion.

E. The motor shall be of squirrel cage, submersible...

xxx

X. GUARANTEE/WARRANTY

xxx

- END -

- (a) Detailed Design Phase and Acquisition of Permits - 75 Calendar days  
(b) Construction Phase - 255 Calendar days  
(c) Post Construction (Commissioning/Process Proving) Phase - 30 Calendar days

Total Project Duration is Three Hundred Sixty (360) Calendar days.

xxx

V. CONCEPTUAL DESIGN/SPECIFICATION/  
PARAMETERS/REQUIREMENTS

1. WATER TREATMENT FACILITIES

a. General Information and requirements

INFLUENT QUALITY		EFFLUENT QUALITY	
Characteristics	Raw Water	2017 PNSDW Standards	Design/Target Objectives
1. Turbidity (NTU)	500	5	1.0 or less
2. Apparent Color	<u>500</u>	10	5.0 or less
3. E. Coli	Positive	Negative/Absent	Negative/Absent

2. Tube Settlers Clarifier System

This shall be inclusive of all electro-mechanical works, appurtenances, installation, start-up and supervision within WTP System. All components of Clarifier System, as delineated below, shall meet the WTP maximum flow capacity of 5MLD.

- Intake Pump with Soft Starter and Appurtenances
- Flocculation and Coagulation Tanks
- Tube Settlers Clarifier Systems
- Yard Piping, Valves, Fittings, and Accessories
- Local Control Panel

3. Solid-Liquid Separation/Filtration Process – use Flat-Sheet Ultrafiltration Membrane Modules

xxx

VI. SUBMERSIBLE PUMP

xxx

~~D. The in-line booster pump and motor shall be horizontally installed inside a steel shroud and submersible in nature. The equipment must have installed a DEFENDER smart device as a standard feature to protect the electric pump and motor from electrochemical corrosion and galvanic currents, passivating the steel so as to create a further safety barrier against corrosion.~~

D. The motor shall be of squirrel cage, submersible...

xxx

X. GUARANTEE/WARRANTY

xxx

XI. EQUIPMENT/MATERIALS SPECIFICATION  
As attached

Sal

7

h


8



<p>Section VII. Drawings</p> <p><u>Site Development Plan (Sheet 1/1), page 93</u></p> <p><u>Bar Chart, page 94</u></p>	<p>Section VII. Drawings</p> <p><u>Site Development Plan (Sheet 1/2)</u></p> <p><u>Process Flow Diagram (Sheet 2/2)</u></p> <p><u>Bar Chart</u></p> <p><u>As attached</u></p>
<p>Section VIII. Bill of Quantities</p> <p>SCHEDULE OF RATES AND PRICES</p> <p>Schedule No. 1 Plant and Equipment Supplied and to be Installed by Contractor</p> <p>xxx</p> <p>C. TREATMENT FACILITY PROCESSES &amp; TECHNOLOGY AND CIVIL WORKS</p> <p>C.1 WTP Treatment Process and Technology</p> <p>1. 5MLD (Two Trains at 500NTU) <u>Lamella Clarifier System</u> inclusive of all electro-mechanical works, appurtenances, installation, star-up and supervision within WTP System</p> <p>a. Intake Pump with Soft Starter and Appurtenances</p> <p>b. Flocculation and Coagulation Tanks with mixers and Ancillaries</p> <p>c. <u>Lamella Clarifier Systems</u></p> <p>d. Yard Piping, Valves, Fittings, and Accessories</p> <p>e. Local Control Panel</p> <p>xxx</p>	<p>Section VIII. Bill of Quantities</p> <p>SCHEDULE OF RATES AND PRICES</p> <p>Schedule No. 1 Plant and Equipment Supplied and to be Installed by Contractor</p> <p>xxx</p> <p>C. TREATMENT FACILITY PROCESSES &amp; TECHNOLOGY AND CIVIL WORKS</p> <p>C.1 WTP Treatment Process and Technology</p> <p>1. 5MLD (Two Trains at 500NTU) <u>Tube Settlers Clarifier System</u> inclusive of all electro-mechanical works, appurtenances, installation, star-up and supervision within WTP System</p> <p>a. Intake Pump with Soft Starter and Appurtenances</p> <p>b. Flocculation and Coagulation Tanks with mixers and Ancillaries</p> <p>c. <u>Tube Settlers Clarifier Systems</u></p> <p>d. Yard Piping, Valves, Fittings, and Accessories</p> <p>e. Local Control Panel</p> <p>xxx</p>

This shall form an integral part of the Bid Documents.

For guidance and information of all concerned.

  
JON LOUIE A. SANCHEZ  
Chairperson, BAC

  
Received by the Bidder

\_\_\_\_\_  
Date \_\_\_\_\_



## XI. EQUIPMENT/MATERIALS SPECIFICATION

The material, for the Supply, Build, Installation, Commissioning & Process Proving of 5MLD Surface Water Treatment Plant at Brgy. Mabolo, Naga City shall conform to the manufacturer's specification which are derived from engineering principles, industry experiences, and the aforementioned standards specification

All materials shall be brand new, previously unused, and in first class condition. Bidders must state here either "Comply" or "Not Comply" against each of the specifications stating the corresponding performance parameter of the equipment offered. Statements of "Comply" or "Not Comply" must be supported by evidence in a Bidders Bid and cross-referenced to that evidence. Evidence shall be in the form of manufacturer's un-amended sales literature, unconditional statements of specification and compliance issued by the manufacturer, samples, independent test data etc., as appropriate.

A statement that is not supported by evidence or is subsequently found to be contradicted by the evidence presented will render the Bid under evaluation liable for rejection. A statement either in the Bidders statement of compliance or the supporting evidence that is found to be false either during Bid evaluation, post-qualification or the execution of the Contract may be regarded as fraudulent and render the Bidder or supplier liable for prosecution subject to the provisions of IIB Clause 3.1(a)(ii).

ITEM NO.	SPECIFICATION	STATEMENT OF COMPLIANCE
<b>1</b>	<b>INTAKE STRUCTURE</b>	
	<b>CAPACITY: 5.0MLD</b>	
<b>1.a</b>	<b>SUBMERSIBLE PUMP</b>	
	Number of units – 1unit	
	Service flow rate – 227m3/hr	
	Service head – 20m	
	Power consumption at duty point – 26kW	
	Maximum power consumption – 26.4kW	
	Max. pump efficiency (Best efficiency point) – 77.6%	
	Rotation speed – 3495 1/min	
	Defender Corrosion Protection System – as a standard feature	
	Minimum Service Factor – 1.15	
<b>2</b>	<b>CLARIFIER (Two Trains at 500 NTU)</b>	
	<b>CAPACITY: 5.0MLD</b>	
<b>2.a</b>	<b>Intake Pump with Soft Starter and Appurtenances</b>	
<b>2.b</b>	<b>Flocculation and Coagulation Tanks</b>	
<b>2.c</b>	<b>Tube Settlers Clarifier System</b>	
<b>2.d</b>	<b>Yard Piping, Valves, Fittings and Accessories</b>	

Handwritten signatures and initials are present below the table, including a large signature on the left, a signature on the right, and several initials and marks at the bottom.

2.e	<b>Local Control Panel</b>	
	*All components of Clarifier System shall meet the WTP maximum flow capacity of 5MLD.	
3	<b>FLAT SHEETS ULTRAFILTRATION (Two Trains at 500 NTU)</b>	
	<b>CAPACITY: 5.0MLD</b>	
3.a	<b>FLAT SHEET UF MEMBRANE MODULES</b>	
	Membrane Material – Polymeric	
	Filtration Mode – Outside-in, suction based principle	
	Filter Pore Size – 0.03 micron (minimum) to 0.05 micron (maximum)	
	Membrane Technology – Polymeric materials must be laser welding technology with multiple filtrate outlets and without damage on the membrane layer	
	Minimum Flux Rate – Based on the bidder's design option as long as it meets the WTP maximum flow capacity of 5MLD.	
	Operating Suction Pressure – Uniform pressure distribution over the entire surface of the membrane.	
	Maximum Backwash Pressure – 3 bars	
	Water Recovery Rate – 95% and above for treated water < 25 NTU Turbidity	
3.b	<b>ON-LINE MONITORING DEVICE AND COAGULANT DOSING SYSTEM</b>	
	a) Raw Water Turbidity Meter	
	b) Raw Water pH Meter	
	c) Raw Water Flow Meter	
	d) Treated Water Turbidity Meter	
	e) Treated Water Chlorine and pH Meter	
	f) Treated Water Flow Meter	
	g) Level Switch	
	h) Pressure Transmitter	
	i) Control Panel with Chemview Control System	
3.c	<b>ACH CHEMICAL DOSING EQUIPMENT</b>	
	Ranges: $\pm 10$ Streaming Current Units (SCU)	
	Accuracy: $\pm 1\%$ of full scale	
	Repeatability: 1%	
	Resolution: 0.01 SCU	
	Response Time: 20seconds	
	Operating Temperature: 0-50°C	
3.d	<b>FLOWMETERS</b>	
	In conformance to LWUA Standards Specifications for flowmeters.	
3.e	<b>HYPOCHLORINATOR</b>	
	Latest model in the market complete with motor and mixing tank including all piping works and accessories.	
3.f	<b>ULTRAFILTRATION FACILITIES</b>	
	Fully automated.	

4

2

Saleh

1

Saleh

5

h

7

*\*the equipment and corresponding specifications indicated above are minimum requirements and may be modified, or replaced, with justifications included in the bid documents. The final equipment and specifications proposed in the bid will still be subject to the evaluation of the bids and awards committee (BAC).*

This is to certify that we/I have prepared and /or checked and reviewed the Technical Specifications stated

Very truly yours,

\_\_\_\_\_  
Authorized Representative  
Signature Over Printed Name

\_\_\_\_\_  
Position Title

Name of Firm : \_\_\_\_\_  
Address: \_\_\_\_\_  
Date Accomplished: \_\_\_\_\_

*[Handwritten mark]*

*[Handwritten mark]*

*[Handwritten signature]*



*[Handwritten mark]*

*[Handwritten signature]*

*[Handwritten signature]*

*[Handwritten mark]*

*[Handwritten mark]*



Site Development Plan

Scale: 1:500M



Republic of the Philippines  
METROPOLITAN WATER DISTRICT  
40 J. M. Alvarado Avenue, Naga City

PREPARED BY:  
SHARMA, J. BRACIA  
P. 000-A, P. 000

CHECKED BY:  
SONJUN G. MILLARES  
DS - SNA, P. 000


RECOMMENDING OFFICIAL:  
VICENTE ANNETO D. RUBIO  
DS - SNA, P. 000

APPROVED:  
VIRGILIO B. LUANSING I  
General Manager

PROJECT TITLE/LOCATION:  
PROPOSED SUPPLY, BUILD, COMMISSIONING AND PROCESS PROVING  
OF FIVE (5) MLD BICOL RIVER SURFACE WATER TREATMENT PLANT

SHEET NO.:  
1  
2  
Date: 09-11-2020





Process Flow Diagram

<p>Republic of the Philippines <b>METROPOLITAN WATER DISTRICT, INC.</b> 40 J. M. Arellano Avenue, Naga City</p>	<p>PREPARED BY: SHARMA, BRACIA PP004, P002</p>	<p>CHECKED BY: SONJIN U. MILLARES DC - DIA, R002</p>	<p>REVIEWED BY: VICENTE AMARILLO D. RUBIO DC - DIA, R002</p>	<p>APPROVED: VIRGILIO B. LUANSING I (General Manager)</p>	<p>PROJECT DESCRIPTION: PROPOSED SUPPLY, BUILD, COMMISSIONING AND PROCESS PROVING OF FIVE (5) MLD BICOL RIVER SURFACE WATER TREATMENT PLANT</p>	<p>SHEET: 2 OF 2 Page 2 Diagram</p>	<p>DATE: 20-04-2020</p>
---	--	--	--	---	---	---	-------------------------




ENGINEERING AND ENVIRONMENT DEPARTMENT  
IMPLEMENTATION SCHEDULE (BAR CHART)

SUPPLY, BUILD, INSTALLATION, COMMISSIONING AND PROCESS PROVING OF FIVE (5) MLD BICOL RIVER SURFACE WATER TREATMENT PLANT  
(INFRA 2320-012)

Site: Paglacon, Bgy. Mabolo, Naga City

IMPLEMENTATION SCHEDULE (BAR CHART)



LEGEND

Planned

Prepared by

SHARWINNE E. BRACIA  
APPROVA

Checked By

BONJURE D. MELLARES  
DCC PCCCI

Recommendation Approval

VICENTE ANGELO D. RUBIO  
DCC SED & DCC AGM GR/S

Approved

VIRGILIO B. LUANING  
General Manager A