Standard Form Number: SF-GOOD-30 Revised on: May 24, 2004

Republic of the Philippines METROPOLITAN NAGA WATER DISTRICT

40 J. Miranda Avenue, Naga City Telephone Number: (054)472-1685/473-7813

Fax Number: (054)473-9288 E-mail Add.: mnwdbac@yahoo.com

SUPPLEMENTAL/BID BULLETIN February 8, 2021

ADDENDUM NO. 01

PROJECT: Supply and Delivery of Materials and Fittings to be Carried on Stock (GOODS 2021-001)

This addendum is issued to modify or amend items in Section VII. Technical Specifications of the bidding documents of the above stated project.

PER PHILGEPS POSTING	PER ADDENDUM
Section VII. Technical Specifications	Section VII. Technical Specifications
1 LOT – SUPPLY AND DELIVERY OF MATERIALS AND FITTINGS TO BE CARRIED ON STOCK	1 LOT – SUPPLY AND DELIVERY OF MATERIALS AND FITTINGS TO BE CARRIED ON STOCK
Specifications:	Specifications:
xxx	xxx
G.I. PIPE 1/2" Ø x 6m Sch. 40, <u>8 kgs. weight</u> , Std. MTE x MTE, HEAVY GAUGE, 1000, pcs	G.I. PIPE 1/2" Ø x 6m Sch. 40, 7.662 kgs. minimum weight, Std. MTE x MTE, HEAVY GAUGE, 1000, pcs
xxx	xxx

This shall form an integral part of the Bid Documents.

For guidance and information of all concerned.

7	JON LOUIE A. SANCHEZ Chairperson, BAC	1
	Received by the Bidder	