

Republic of the Philippines
METROPOLITAN NAGA WATER DISTRICT
40 J. Miranda Avenue, Naga City
Telephone Number: (054)472-1685/473-7813
Fax Number: (054)473-9288
E-mail Add.: mnwdbac@yahoo.com

SUPPLEMENTAL/BID BULLETIN
May 3, 2021

ADDENDUM NO. 04

PROJECT: Supply and Delivery of Brand New Submersible Pumps and Motors for Pumping Stations Use (GOODS 2021-003)

This addendum is issued to modify or amend items in Section VII. Technical Specifications of the bidding documents posted at PhilGEPS Website of the above stated project due to typographical error.

PER PHILGEPS POSTING	PER ADDENDUM
Item No. 1 Submersible Pump & Motor (Brand New) for Pacol 3 and San Isidro I PS, 2 Sets A. Operating Requirements: 1. Minimum capacity at design head, lps: 198 m ³ /hr. xxx	Item No. 1 Submersible Pump & Motor (Brand New) for Pacol 3 and San Isidro I PS, 2 Sets A. Operating Requirements: 1. Minimum capacity at design head, lps : 198 m ³ /hr. xxx
Item No. 2 Submersible Pump & Motor (Brand New) for Carolina 1 and Monte Cielo PS, 2 Sets A. Operating Requirements: 1. Minimum capacity at design head, lps: 148 m ³ /hr. xxx	Item No. 2 Submersible Pump & Motor (Brand New) for Carolina 1 and Monte Cielo PS, 2 Sets A. Operating Requirements: 1. Minimum capacity at design head, lps : 148 m ³ /hr. xxx
Item No. 3 Submersible Pump & Motor (Brand New) for San Isidro II PS, 1 Set A. Operating Requirements: 1. Minimum capacity at design head, lps: 180 m ³ /hr. xxx	Item No. 3 Submersible Pump & Motor (Brand New) for San Isidro II PS, 1 Set A. Operating Requirements: 1. Minimum capacity at design head, lps : 180 m ³ /hr. xxx
Item No. 4 Submersible Pump & Motor (Brand New) for Cararayan I and Del Rosario PS, 2 Sets A. Operating Requirements: 1. Minimum capacity at design head, lps: 149 m ³ /hr. xxx	Item No. 4 Submersible Pump & Motor (Brand New) for Cararayan I and Del Rosario PS, 2 Sets A. Operating Requirements: 1. Minimum capacity at design head, lps : 149 m ³ /hr. xxx

Standard Form Number: SF-GOOD-30
Revised on: May 24, 2004

PER PHILGEPS POSTING	PER ADDENDUM
<div>Item No. 5</div> <div>Submersible Pump & Motor (Brand New) for Cararayan III PS, 1 Set</div> <div>A. Operating Requirements:<div>1. Minimum capacity at design head, lps: 126 m³/hr.</div></div> <div>xxx</div>	<div>Item No. 5</div> <div>Submersible Pump & Motor (Brand New) for Cararayan III PS, 1 Set</div> <div>A. Operating Requirements:<div>1. Minimum capacity at design head, lps: 126 m³/hr.</div></div> <div>xxx</div>
<div>Item No. 7</div> <div>Submersible Pump & Motor (Brand New) for Villa Sorabella PS, 1 Set</div> <div>A. Operating Requirements:<div>1. Minimum capacity at design head, lps: 36 m³/hr.</div></div> <div>xxx</div>	<div>Item No. 7</div> <div>Submersible Pump & Motor (Brand New) for Villa Sorabella PS, 1 Set</div> <div>A. Operating Requirements:<div>1. Minimum capacity at design head, lps: 36 m³/hr.</div></div> <div>xxx</div>
<div>Item No. 8</div> <div>Submersible Pump & Motor (Brand New) for San Agustin PS, 1 Set</div> <div>A. Operating Requirements:<div>1. Minimum capacity at design head, lps: 54 m³/hr.</div></div> <div>xxx</div>	<div>Item No. 8</div> <div>Submersible Pump & Motor (Brand New) for San Agustin PS, 1 Set</div> <div>A. Operating Requirements:<div>1. Minimum capacity at design head, lps: 54 m³/hr.</div></div> <div>xxx</div>
<div>Item No. 9</div> <div>Submersible Pump & Motor (Brand New) for Carangcang PS, 1 Set</div> <div>A. Operating Requirements:<div>1. Minimum capacity at design head, lps: 36 m³/hr.</div></div> <div>xxx</div>	<div>Item No. 8</div> <div>Submersible Pump & Motor (Brand New) for Carangcang PS, 1 Set</div> <div>A. Operating Requirements:<div>1. Minimum capacity at design head, lps: 36 m³/hr.</div></div> <div>xxx</div>

This shall form an integral part of the Bid Documents.

For guidance and information of all concerned.


JON LOUIE A. SANCHEZ
Chairperson, BAC 

Received by the Bidder

Date
