

Republic of the Philippines
METROPOLITAN NAGA WATER DISTRICT
40 J. Miranda Avenue, Naga City
Telephone Number: (054)472-1685/473-7813
Fax Number: (054)473-9288
E-mail Add.: mnwdbac@yahoo.com

SUPPLEMENTAL/BID BULLETIN
May 5, 2021

ADDENDUM NO. 05

PROJECT: Supply and Delivery of Various Sizes of Pressure Release Valves (GOODS 2021-005)

This addendum is issued to modify or amend items in Section I. Invitation to Bid and Section VII. Technical Specifications of the bidding documents posted at PhilGEPS, MNWD Website, and conspicuous places within the MNWD premises of the above stated project.

| PER PHILGEPS POSTING | PER ADDENDUM |
|--|---|
| <p>Section I. Invitation to Bid</p> <p>Invitation to Bid for SUPPLY AND DELIVERY OF VARIOUS SIZES OF PRESSURE RELEASE VALVES</p> <p>1. The METROPOLITAN NAGA WATER DISTRICT (MNWD) through its approved Corporate Budget, intends to apply the sum of ONE MILLION FOUR HUNDRED TWENTY-TWO THOUSAND THREE HUNDRED FIFTY-ONE PESOS AND 58/100 (Php 1,422,351.58) Only, being the Approved Budget for the Contract (ABC) to payments under the contract for the SUPPLY AND DELIVERY OF VARIOUS SIZES OF PRESSURE RELEASE VALVES, PROJECT NO. GOODS 2021-005. Bids received in excess of the ABC shall be automatically rejected at bid opening.</p> <p>2. The <i>MNWD</i> now invites bids for the above Procurement Project. Delivery of the Goods is required by THIRTY (30) CALENDAR DAYS. Bidders should have completed, within the last two (2) years from the date of submission and receipt of bids, a contract similar to the Project. The description of an eligible bidder is contained in the Bidding Documents, particularly, in Section II (Instructions to Bidders). xxx</p> | <p>Section I. Invitation to Bid</p> <p>Invitation to Bid for SUPPLY AND DELIVERY OF VARIOUS SIZES OF PRESSURE RELEASE VALVES</p> <p>1. The METROPOLITAN NAGA WATER DISTRICT (MNWD) through its approved Corporate Budget, intends to apply the sum of ONE MILLION FOUR HUNDRED TWENTY-TWO THOUSAND THREE HUNDRED FIFTY-ONE PESOS AND 58/100 (Php 1,422,351.58) Only, being the Approved Budget for the Contract (ABC) to payments under the contract for the SUPPLY AND DELIVERY OF VARIOUS SIZES OF PRESSURE RELEASE VALVES, PROJECT NO. GOODS 2021-005. Bids received in excess of the ABC shall be automatically rejected at bid opening.</p> <p>2. The <i>MNWD</i> now invites bids for the above Procurement Project. Delivery of the Goods is required by SIXTY (60) CALENDAR DAYS. Bidders should have completed, within the last two (2) years from the date of submission and receipt of bids, a contract similar to the Project. The description of an eligible bidder is contained in the Bidding Documents, particularly, in Section II (Instructions to Bidders). xxx</p> |

Standard Form Number: SF-GOOD-30
Revised on: May 24, 2004

| PER PHILGEPS POSTING | PER ADDENDUM |
|--|---|
| <p>Section VII. Technical Specifications</p> <ol style="list-style-type: none"> 1. 3"Ø PRV (Km. 11 Carolina), 1 piece 2. 8"Ø PRV (Km. 9, Km.5 Cararayan Proper, Almeda Hi-way), 2 pieces 3. 12"Ø PRV (Z-7 San Rafael, Del Rosario), 1 piece <p>Specifications:</p> <p>Main Valve Pattern: Globe (Straight Flow) Body and Bonnet Material: Ductile Iron Body Coating: Epoxy Connection Type: Flange Type Position Indicator: Stainless Steel Body/ Bonnet Bolts & Nuts: Stainless Steel Diaphragm: EPDM/reinforce Elastomer Ball valve: Stainless Steel Spring: Stainless Steel Drain Plug: Stainless Steel Nut: Stainless Steel Opening Speed Control: Stainless Steel Pilot Valve: Bronze Tubing: Stainless Braided Hose Level Indicator: Glass Elastomer Copper Alloy</p> | <p>Section VII. Technical Specifications</p> <ol style="list-style-type: none"> 1. 3"Ø PRV (Km. 11 Carolina), 1 piece 2. 8"Ø PRV (Km. 9, Km.5 Cararayan Proper, Almeda Hi-way), 2 pieces 3. 12"Ø PRV (Z-7 San Rafael, Del Rosario), 1 piece <p>Specifications:</p> <p>Main Valve Pattern: Globe (Straight Flow) Body and Bonnet Material: Ductile Iron Body Coating: Epoxy Connection Type: Flange Type Position Indicator: Stainless Steel Body/ Bonnet Bolts & Nuts: Stainless Steel Diaphragm: EPDM/reinforce Elastomer Ball valve: Stainless Steel Spring: Stainless Steel Drain Plug: Stainless Steel Nut: Stainless Steel Opening Speed Control: Stainless Steel Pilot Valve: Bronze Tubing: Stainless Braided Hose Level Indicator: Glass Elastomer Copper Alloy <u>Pressure Range: 30 - 100 psi</u></p> |

This shall form an integral part of the Bid Documents.

For guidance and information of all concerned.


JON LOUIE A. SANCHEZ
Chairperson, BAC

Received by the Bidder

Date _____