Standard Form Number: SF-GOOD-30

Revised on: May 24, 2004

Republic of the Philippines

METROPOLITAN NAGA WATER DISTRICT

40 J. Miranda Avenue, Naga City Telephone Number: (054) 472-1685/473-7813 Fax Number: (054) 473-9288

E-mail Add.: mnwdbac@yahoo.com

SUPPLEMENTAL/BID BULLETIN March 6, 2024

ADDENDUM NO. 02

SUPPLY, DELIVERY, INSTALLATION AND COMMISSIONING OF BRAND-NEW DIESEL ELECTRIC PROJECT: **GENERATING SETS FOR CAROLINA IV AND PACOL V PUMPING STATIONS (GOODS 2024-002)**

This addendum is issued to modify or amend the items in Section VII. Technical Specifications of the bidding documents posted at the PhilGEPS and MNWD Website of the above-stated project due to typographical error, to wit:

PER PHILGEPS POSTING Section VII. Technical Specifications		PER ADDENDUM Section VII. Technical Specifications	
	XXX	XXX	
	A. Technical Data	A. Technical Data	
	PRP Continuous power KVA: 168.8-196.9	PRP Continuous power KVA: 168.8-196.9	
	PRP Continuous power KW: 135.04-157.52	PRP Continuous power KW: 135.04-157.52	
	LTP Standby power KVA: 187.5-218.75	LTP Standby power KVA: 187.5-218.75	
	LTP Standby Power KW: 150-175	LTP Standby Power KW: 150-175	
	Power Factor: 0.8	Power Factor: 0.8	
	Voltage (VAC): 460	Voltage (VAC): 460	
	Frequency: 60HZ	Frequency: 60HZ	
	Speed: 1800	Speed: 1800	
	Governor Type: Mechanical	Governor Type: Mechanical	
	Battery Type: 12V	Battery Type: 12V	
	Bore and Stroke: 105x135	Bore and Stroke: 105-114 x 135	
	XXX	XXX	

This shall form an integral part of the Bid Documents.

For guidance and information of all concerned.

JON LOUSE A. SANCHEZ Chairperson, BAC

Received by the Bidder:

(Signature	over	Printed	Name,
Dato:			