

[My PhilGEPS](#)
[My Organization](#)
[My Profile](#)
[Opportunities](#)
[Catalogue](#)
[Directory](#)
[About PhilGEPS](#)

Tuesday, February 22, 2022 12:00 PM
 Venus Solano MNWD
 » [Log-out](#)

Bid Notice Abstract

[Detail Tracking Report](#)

Request for Quotation (RFQ)

Reference Number 8452314
Procuring Entity METROPOLITAN NAGA WATER DISTRICT
Title Supply and Delivery of Water Meter Insert (PR#22-01-0022)
Area of Delivery Camarines Sur

 [Printable Version](#)

Solicitation Number:	PR 22-01-0022	Status	Active
Trade Agreement:	Implementing Rules and Regulations	Associated Components	1
Procurement Mode:	Negotiated Procurement - Small Value Procurement (Sec. 53.9)		
Classification:	Goods		
Category:	Water Service Connection Materials/Fittings	Bid Supplements	0
Approved Budget for the Contract:	PHP 504,000.00		
Delivery Period:			
Client Agency:		Document Request List	2
Contact Person:	Venus C. Solano Procurement Analyst A 40 J.Miranda Ave., Naga City Camarines Sur Philippines 4400 63-54-4737813 Ext.117 63-54-4739288 mnwdbac@yahoo.com	Date Published	22/02/2022
		Last Updated / Time	22/02/2022 12:00 AM
		Closing Date / Time	25/02/2022 5:00 PM

Description

1 WATER METER INSERT 1/2" Ø (SHORT)

Specifications:

Register Assembly ~ Self-contained register hermitically sealed compartment straight reading, 5 digits register, high impact glass lens & abrasion resistant

Meter register In cubic meter 10,000

Anti-magnetic mechanism and backflow

Anti-Reverse Mechanism with central star for leak detection

Working condition: water temperature 50° C

Water Pressure: ≥ 10 bars

Standard: ISO 4064

Minimum Performance:

Maximum Flow Rate (Qmax) = 3m³/hr

Nominal Flow Rate (Qmax) = 1.5m³/hr

Transitional Flow Rate (Qt) = 120 L/hr

Minimum Flowrate (Qmin) = 30L/hr

Accuracy (Qmax - Qt) = ± 2%

Accuracy (Qt - Qmin) = ± 5%

Measuring Chamber has stainless steel adjustment screw for flow control

Strainer Screen - Central strainer at least 14 to 16 microns

Can fit & perform accurately with ASIAM, JET, E-JET, EVJET casing

Dimensions: Height 85mm with central strainer

Diameter: 76mm

1800 pcs

Note:

1. VAT Inclusive

2. FOB MNWD, Naga City

3. Partial Delivery shall not be accepted

Documentary Requirements to submit:

1. Mayor's/Business Permit

2. PhilGEPS Registration Number

3. Income/Business Tax Returns

4. Omnibus Sworn Statement

****Incomplete or non-submission of the required Documentary Requirements shall be automatically disqualified**

Line Items