

Standard Form Number: SF-GOOD-30
 Revised on: May 24, 2004

Republic of the Philippines
METROPOLITAN NAGA WATER DISTRICT
 40 J. Miranda Avenue, Naga City
 Telephone Number: (054)472-1685/473-7813
 Fax Number: (054)473-9288
 E-mail Add.: mnwdbac@yahoo.com

SUPPLEMENTAL/BID BULLETIN
July 29, 2022

ADDENDUM NO. 03

PROJECT: **Supply and Delivery of Various Sizes of uPVC Riser Pipes and Fittings (GOODS 2022-002)**

This addendum is issued to modify or amend items in Section VII. Technical Specifications of the bidding documents posted at PhilGEPS Website of the above stated project.

PER ADDENDUM NO. 01	PER ADDENDUM NO. 03
<p>Philippine Government Electronic Procurement System (PhilGEPS) Bid Notice Abstract Description</p> <p>ITEM NO. DESCRIPTION QTY. UNIT</p> <p>1 uPVC Riser Pipes 6"Ø x 10' standard heavy duty thickness 18mm, outside diameter 168mm ultimate breaking load in kgs., 21,000, safe pulling load in kgs. 11,500, safety allowable hydrostatic pressure in kgs/cm²-17 for Cararayan 2, Carolina 1, 2 & 3, and Pacol 1 Pumping Stations 99 pieces</p> <p>2 uPVC Riser Pipes 5"Ø x 10' standard heavy duty thickness 18mm, outside diameter 140mm ultimate breaking load in kgs. 16,000, safe pulling load in kgs. 9,000, safety allowable hydrostatic pressure in kgs/cm²-16 for Magdalena Pumping Station 27 pieces</p> <p>xxx</p>	<p>Philippine Government Electronic Procurement System (PhilGEPS) Bid Notice Abstract Description</p> <p>ITEM NO. DESCRIPTION QTY. UNIT</p> <p>1 uPVC Riser Pipes 6"Ø x 10' standard heavy duty thickness 18mm, outside diameter 168mm ultimate breaking load in kgs., 21,000, safe pulling load in kgs. 11,500, safety allowable hydrostatic pressure in kgs/cm²-17 for Cararayan 2, Carolina 1, 2 & 3, and Pacol 1 Pumping Stations 99 pieces</p> <p>2 uPVC Riser Pipes 5"Ø x 10' standard heavy duty thickness 18mm, outside diameter 140mm ultimate breaking load in kgs. 16,000, safe pulling load in kgs. 9,000, safety allowable hydrostatic pressure in kgs/cm²-16 for Magdalena Pumping Station 27 pieces</p> <p>xxx</p>
<p>Section VII. Technical Specifications Technical Specifications</p> <p>1. 99 pieces of uPVC Riser Pipes 6"Ø x 10' standard heavy duty thickness 18mm, outside diameter 168mm ultimate breaking load in kgs., 21,000, safe pulling load in kgs. 11,500, safety allowable hydrostatic pressure in kgs/cm²-17 for Cararayan 2, Carolina 1, 2 & 3, and Pacol 1 Pumping Stations</p> <p>2. 27 pieces of uPVC Riser Pipes 5"Ø x 10' standard heavy duty thickness 18mm, outside diameter 140mm ultimate breaking load in kgs. 16,000, safe pulling load in kgs. 9,000, safety allowable hydrostatic pressure in kgs/cm²-16 for Magdalena Pumping Station</p> <p>xxx</p>	<p>Section VII. Technical Specifications Technical Specifications</p> <p>1. 99 pieces of uPVC Riser Pipes 6"Ø x 10' standard heavy duty thickness 18mm, outside diameter 168mm ultimate breaking load in kgs., 21,000, safe pulling load in kgs. 11,500, safety allowable hydrostatic pressure in kgs/cm²-17 for Cararayan 2, Carolina 1, 2 & 3, and Pacol 1 Pumping Stations</p> <p>2. 27 pieces of uPVC Riser Pipes 5"Ø x 10' standard heavy duty thickness 18mm, outside diameter 140mm ultimate breaking load in kgs. 16,000, safe pulling load in kgs. 9,000, safety allowable hydrostatic pressure in kgs/cm²-16 for Magdalena Pumping Station</p> <p>xxx</p>

This shall form an integral part of the Bid Documents.

For guidance and information of all concerned.


JON LOUIE A. SANCHEZ
 Chairperson, BAC

Received by the Bidder:

 (Signature over Printed Name)

Date: _____