

Standard Form Number: SF-GOOD-30  
 Revised on: May 24, 2004

Republic of the Philippines  
**METROPOLITAN NAGA WATER DISTRICT**  
 40 Miranda Avenue, Concepcion Pequeña, Naga City  
 Telephone Number: (054) 472-1685/473-7813  
 Fax Number: (054) 473-9288  
 E-mail Add.: [mnwdbac@yahoo.com](mailto:mnwdbac@yahoo.com)

**SUPPLEMENTAL/BID BULLETIN**  
**June 2, 2026**

**ADDENDUM NO. 09**

**PROJECT: SUPPLY, DELIVERY, INSTALLATION AND COMMISSIONING OF VARIOUS SIZES ELECTROMAGNETIC FLOWMETERS AND DATA LOGGERS (GOODS 2026-006)**

This addendum is issued to modify or amend the items in Section VII. Technical Specifications of the bidding documents posted at the PhilGEPS Website of the above-stated project, to wit:

PER PHILGEPS POSTING	PER ADDENDUM
Section VII. Technical Specifications  <b>1. Electromagnetic Flowmeter DN150 (6"), 9 units</b> Technical Specifications: Power Source: 100 to 220 VAC 60 Hz / 24 VDC  Xxx	Section VII. Technical Specifications  <b>1. Electromagnetic Flowmeter DN150 (6"), 9 units</b> Technical Specifications: Power Source: 100 to 220 VAC 60 Hz <b>and</b> 24 VDC  Xxx
<b>2. Electromagnetic Flowmeter DN100 (4"), 4 units</b> Technical Specifications: Power Source: 100 to 220 VAC 60 Hz / 24 VDC  Xxx	<b>2. Electromagnetic Flowmeter DN100 (4"), 4 units</b> Technical Specifications: Power Source: 100 to 220 VAC 60 Hz <b>and</b> 24 VDC  Xxx
<b>3. Electromagnetic Flowmeter DN80 (3"), 4 units</b> Technical Specifications: Power Source: 100 to 220 VAC 60 Hz / 24 VDC  Xxx	<b>3. Electromagnetic Flowmeter DN80 (3"), 4 units</b> Technical Specifications: Power Source: 100 to 220 VAC 60 Hz <b>and</b> 24 VDC  Xxx

This shall form an integral part of the Bid Documents. For guidance and information of all concerned.

  
**JON LOUIE A. SANCHEZ**  
 Chairperson, BAC

Received by the Bidder:

\_\_\_\_\_  
 (Signature over Printed Name)  
 Date: \_\_\_\_\_