

My PhilGEPS

My Organization

My Profile

Opportunities

Catalogue

Directory

About PhilGEPS

Pending Task | Notices | Award Notices

Wednesday, February 12, 2025 02:11 PM

Venus Solano MNWD

Log-out

Bid Notice Abstract

[Detail Tracking Report](#)

Request for Quotation (RFQ)

Reference Number 11743173

Procuring Entity METROPOLITAN NAGA WATER DISTRICT

Title Supply of Labor and Materials for Distribution Transformer at Villa Sorabella PS (PR#25-01-007)

Area of Delivery Camarines Sur

 [Printable Version](#)

| | | | |
|--|---|------------------------------|---------------------|
| Solicitation Number: | RFQ 0011 | Status | Active |
| Trade Agreement: | Implementing Rules and Regulations | Associated Components | 1 |
| Procurement Mode: | Negotiated Procurement - Small Value Procurement (Sec. 53.9) | Bid Supplements | 0 |
| Classification: | Goods | Document Request List | 4 |
| Category: | Power Generation and Distribution Machinery | Date Published | 11/02/2025 |
| Approved Budget for the Contract: | PHP 299,888.54 | Last Updated / Time | 11/02/2025 12:00 AM |
| Delivery Period: | 30 Day/s | Closing Date / Time | 14/02/2025 1:00 PM |
| Client Agency: | | | |
| Contact Person: | Venus C. Solano Procurement Analyst A 40 J.Miranda Ave., Naga City Camarines Sur Philippines 4400 63-54-4737813 Ext.117 63-54-4739288 mnwdbac@yahoo.com | | |

Description

ITEM NO. ITEM & DESCRIPTION QTY UNIT UNIT PRICE TOTAL COST

1 Distribution Transformer 1 lot

Specification:

Kva:25

Voltage: Pri. 7620/13200v, Sec.240/480V

Polarity: Additive

Percent Impedance: 2.0

Class: OA

Phase: Single

2 units

2 Fuse Link, 3A 3 pcs

3 Cut out & Lighting Arrester Combination 2 sets

4 Lighting Arrester 1 set

5 Connector Compression YHD 200 4 pcs

6 Hotline Clamp 2 pcs

7 THW/ THHN conductor No.6 10 mtrs

B

CASURECO II (see attached CASURECO II SOA)

Technical Requirements:

1. The units must all brand new and manufactured conforming to IEEE/ ANSI standards.

2. The units shall be oil immersed, Self Cooled double brushing, 60HZ Pri:7620 / 13200v, Sec: 240/480v, BIL95, turns ratio tolerance: +/-1% with external tap changer.

3. The units shall be furnished with no load manual winding taps at 2-1/2% above and below normal voltage.

4. The core and winding of transformers shall be designed and constructed to give the minimum core loss and shall provide the least percentage ratio of exciting current to full load ampere rating as required by Electric Cooperative/NEA.

5. The units should Passed the required field testing of CASURECO II.

6. The supplier shall guarantee that the units shall be free from all defective workmanship and materials for a period of (1) year after final acceptance of the project. Any defect appearing within the aforesaid period shall be remedied by the supplier at his own expense including testing fees.

7. The supplier must submit a copy of PCB free certificate as required by DENR-EMB upon completion.

8. The supplier must submit a copy of manufacturers Transformers Test result of the said units upon completion.

9. The supplier must submit a copy of CASURECO II Transformer Test Result upon completion.

10. The supplier must submit a clear copy of the nameplates of the distribution Transformer.

11. The units must Conformed with the standard Color ANSI 70 Gray.

12. The nameplate of transformer shall be made of stainless steel with information showing the following:

a.) Serial No., b) Class, c) Phase, d) Frequency, e) Voltage Rating f) KVA Rating, g) Temp Rise C, h) Polarity, i) Percent Imp, j) BIL, k) Total wt, l) Total oil, m) Connection Diagram, n) Name of Manufacturer, o) Installation and Operating Instruction, p) The word "transformer", q) Type of

insulating liquid, r) Conductor Materials for each winding and s) Equipment identification number.
13. The supplier must provide a copy of warranty certificate for the said transformer units.

TOTAL

Note:

1. VAT Inclusive
2. For Villa Sorabella Pumping Station, Naga City
3. Partial Delivery shall not be accepted
4. Warranty: One (1) year

Documentary Requirements to submit:

1. Mayor's/Business Permit
2. PhilGEPS Registration Number / Certificate of Platinum Membership
3. Income/Business Tax Returns (for ABCs above Php 500k)

Incomplete or non-submission of the required Documentary Requirements shall be automatically disqualified

4. Notarized Omnibus Sworn Statement

The supplier may submit NOSS on the date of accomplishing this document (RFQ) or prior to the preparation of award

Line Items

| Item No. | Product/Service Name | Description | Quantity | UOM | Budget (PHP) |
|----------|---|--------------------------|----------|-----|--------------|
| 1 | Power Generation and Distribution Machinery | Distribution Transformer | 1 | Lot | 299,888.54 |

Created by Venus C. Solano

Date Created 10/02/2025

The PhilGEPS team is not responsible for any typographical errors or misinformation presented in the system. PhilGEPS only displays information provided for by its clients, and any queries regarding the postings should be directed to the contact person/s of the concerned party.