

[My PhilGEPS](#) | 
 [My Organization](#) | 
 [My Profile](#) | 
 [Opportunities](#) | 
 [Catalogue](#) | 
 [Directory](#) | 
 [About PhilGEPS](#)

[Pending Task](#) | 
 [Notices](#) | 
 [Award Notices](#)

Tuesday, August 5, 2025 08:34 AM Venus Solano MNWD [» Log-out](#)

## Bid Notice Abstract

[Detail Tracking Report](#)

### Request for Quotation (RFQ)

**Reference Number** 12281438  
**Procuring Entity** METROPOLITAN NAGA WATER DISTRICT  
**Title** Procurement of GPRS Data Logger (PR#25-07-0261)  
**Area of Delivery** Camarines Sur

 [Printable Version](#)

<b>Solicitation Number:</b>	RFQ 0063	<b>Status</b>	Active
<b>Trade Agreement:</b>	Implementing Rules and Regulations	<b>Associated Components</b>	<a href="#">1</a>
<b>Procurement Mode:</b>	Negotiated Procurement - Small Value Procurement (Sec. 53.9)	<b>Bid Supplements</b>	<a href="#">0</a>
<b>Classification:</b>	Goods	<b>Document Request List</b>	<a href="#">0</a>
<b>Category:</b>	Industrial Machinery and Equipment	<b>Date Published</b>	05/08/2025
<b>Approved Budget for the Contract:</b>	PHP 1,906,320.00	<b>Last Updated / Time</b>	05/08/2025 12:00 AM
<b>Delivery Period:</b>	90 Day/s	<b>Closing Date / Time</b>	08/08/2025 1:00 PM
<b>Client Agency:</b>			
<b>Contact Person:</b>	Venus C. Solano Procurement Analyst A 40 J.Miranda Ave., Naga City Camarines Sur Philippines 4400 63-54-4737813 Ext.117 63-54-4739288 mnwdbac@yahoo.com		

**Description**

No. ITEM & DESCRIPTION QTY UNIT UNIT PRICE TOTAL COST  
 1 GPRS DATA LOGGER ONLY  
 Inclusive:  
 a) Standard Pressure Hose  
 b) Quick connect fitting  
 c) 1 year Data Allowance  
 d) Supply, Delivery and Training  
 Communication Module - FOC

Specifications:  
 A. Communication  
 Transmission options: Capable of 4G/ 3G/ 2G  
 Transmission frequency: Minimum of 5 minutes  
 Alarms: Threshold, profile and envelope options  
 Antenna Type: External  
 Direct Connection: Bluetooth via Smart phone Application  
 B. Logging Features  
 Sample Interval: 1 sec - 24 hours  
 Memory: 4GB  
 Data Types: Average, Minimum, Maximum, Standard Deviation  
 C. DIGITAL CHANNEL  
 No. of Digital Inputs: 2 (Forward and Reverse Flow)  
 Max pulse frequency: 1000 Hz  
 Logging Modes: Switches to event pulse interval timing at low pulse rates  
 Meter Index: Digital Totalizer  
 Bi-direction/ Combination: Option to combine two independent pulse streams into a single logged value  
 D. INTERNAL PRESSURE  
 No. of Transducers: 1  
 Internal Pressure range: 0-20 Bar  
 Accuracy: ±0.1% of full range  
 Connection: Male quick release  
 E. PHYSICAL  
 Operating Temperature: 0°C to 60°C or better  
 Humidity: 99% Relative humidity

Protection Classification: IP68 (minimum)

Dimension: 100 x 160 x 44 mm

Case Material: Extruded 6063 Aluminum

**F. POWER**

Internal Battery: Nominal 3.6 Vdc

Battery Chemistry: Lithium Thionyl Chloride

battery life: 5 years based on 15 min. data sending

once per day

**G. SPECIAL FEATURES**

Included software must be capable but not limited to the following:

\*Graphical presentation of data via free online cloud data

base free of charge (compliance upon delivery)

\*Logged data value for previous days of recording

The logger must be capable but not limited to the following:

\*Increase communication up-time

\*Data in one place

\*Reduced set-up time

\* 2 channels (1 pressure, 1 flow)

\*Instantaneous onsite data viewing via bluetooth mobile app

**H. STANDARD ACCESSORIES**

(Compliance upon delivery)

1. Must include necessary fittings and Pressure Hose

2. 10 units Flow Cable for Flow monitoring

3. 1-year data allowance for each logger

**I. ADDITIONAL REQUIREMENTS**

\*Must submit original or computer-generated catalog/ brochure

**J. ADDITIONAL REQUIREMENTS TESTING AND**

**SOFTWARE COMPATIBILITY**

(Compliance upon delivery)

1. The manufacturer should have ISO/IEC

27001:2013 certificates or its updated versions.

2. Supplier should have ISO 9001:2015 and

14001:2015 certificates or its updated versions.

3. Must provide Data logger Manual

4. Minimum one (1) year manufacturer's warranty.

5. Supplier must have Manufacturer's Authorization

Certificate specific to this project

6. In the presence of the owner, the necessary field

testing should be conducted by a qualified

technician of the supplier such as installation,

commissioning and operation of data logged

before acceptance of goods. The data logger must

also be compatible with the existing flow meters. 30 units

**TOTAL**

Note:

1. VAT Inclusive

2. Partial Delivery shall not be accepted

3. FOB, MNWD, Naga City

4. Warranty; One (1) year

Documentary Requirements to submit:

1. Mayor's/Business Permit

2. PhilGEPS Registration Number / Certificate of Platinum Membership

3. Income/Business Tax Returns (for ABCs above Php 500k)

Incomplete or non-submission of the required Documentary Requirements shall be automatically disqualified

4. Notarized Omnibus Sworn Statement

The supplier may submit NOSS on the date of accomplishing this document (RFQ) or prior to the preparation of award

**Line Items**

Item No.	Product/Service Name	Description	Quantity	UDM	Budget (PHP)
1	Industrial Machinery and Equipment	GPRS Data Logger	30	Unit	1,906,320.00

**Created by** Venus C. Solano

**Date Created** 04/08/2025

[Postpone Bid](#) [Cancel Bid](#) [Back](#)

The PhilGEPS team is not responsible for any typographical errors or misinformation presented in the system. PhilGEPS only displays information provided for by its clients, and any queries regarding the postings should be directed to the contact person/s of the concerned party.